



Date 1 June 1993 Number of pages (including this page) 1

To Director
 Abey Hardware Telephone number

Facsimile number 03 338 7960

From Lawrie Baker
 Director
 Masonry Research Centre (G) Telephone number (052) 27 1101

Facsimile number (052) 27 2167

Facsimile message re Test Results

Test: AS2539 - 1984 Wall Ties for Masonry Construction Appendix C.

Tie description: Veneer tremor two-part tie as supplied by Abey Hardware

Summary of results are:

Material	Cavity Width	Characteristic Strength		Characteristic Stiffness kN/mm
		Tension	Compression	
Galv	50	1.23 kN	0.93 kN	> 1.0
Galv	75	1.12	0.93	> 1.0
S.S	50	1.09	1.05	> 1.0
S.S	75	1.14	1.05	> 1.0

Hence all ties are classified as medium duty.

Yours sincerely

Lawrie Baker