



Code 592
Cavity Width Tested 130mm
Tension Tests



Spec No	Strength kN	Stiffness kN/mm
BT1	5.55	7.04
BT2	5.42	10.29
BT3	5.51	8.60
BT4	5.44	7.53
BT5	5.34	7.44
BT6	5.50	8.89

Mean	5.48	8.30
SD	0.08	1.21
Characteristic	5.34	6.30
CV	0.01	0.15

**Code 592
Cavity Width Tested 130mm
Compression Tests**



Spec No	Strength kN	Stiffness kN/mm
BC1	4.57	10.44
BC2	4.43	6.19
BC3	4.22	8.25
BC4	4.39	7.41
BC5	4.57	8.10
BC6	4.12	6.70

Mean	4.40	8.02
SD	0.21	1.58
Characteristic	4.06	5.40
CV	0.05	0.20